



A TO Z NDT SOLUTIONS PVT LTD

(an NABL Approved Company)

STRUCTURE STABILITY CERTIFICATE

We hereby certify that the Existing RCC Framed Vega Schools Structure Building Near, Toll Plaza, NH-8, Kherki Daula, Gurugram, Haryana 122001 been checked by us as per Indian codes and NBC standards for structural safety using non destructive testing:-

Particular	Details
Location	Vega Schools, Near, Toll Plaza, NH-8, Kherki Daula, Gurugram, Haryana 122001
Project	Struture Audit of Existing Structure Structure using Non Destructive Testing for Structure Analysis
Prefer Code	IS 875 for Load IS 456 for RCC Design IS 1893 for Earthquake IS 13311, IS 516 for Non Destructive Testing
Live Load in Structure	3KN/Sqm as per IS 875

I **RAKESH KUMAR** (Chartered Civil Engineer/MCD Empaneled) hereby undertakes as follows: -

1. The school building structure is **safe and stable** for use within the service gravity loading as per Indian codes and NBC standards.
2. Structure is completely checked by me using non destructive testing such as Rebound Hammer, Core Cutting Test and RCC Scanning for analysis the structure under current conditions.
3. The RCC framed had been checked in accordance with IS code & NBC standards.
4. This certificate will not be valid in case any modification was done with information.
5. The certificate is valid for next 3 years.

MR. RAKESH KUMAR

STRUCTURE ENGINEER/STRUCTURE AUDITOR
DIP., B.TECH, M.TECH (STRUCTURE & FOUNDATION)
CHARTERED ENGINEER (INDIA) AM-1781675
MUNICIPAL CORPORATION OF DELHI NO- SE/0445

Authorized Signature

Mr. Rakesh Kumar
Chartered Engineer
Civil/Structures
AM-1781675
MCD Str. Engg- SE/0445

STRUCTURAL ANALYSIS THROUGH NDT



Address: Plot-16, 1st Floor, Maharshi Dayanand Saraswati Marg, Sec-88, Near RPS Chowk, Faridabad-121002, Haryana,
Phone: 0129-4103532, 8469769160. Email ID: hod@atozndt.com